

**Tabela Regulacyjna dla systemu ciepłowniczego
EC Wrocław i EC Czechnica na sezon grzewczy 2020/2021
Obowiązuje od dnia 01.10.2020 r.**

Parametry obliczeniowe 130/65 °C

EC Wrocław

t_{zew}	$T1_G$	$T1_D$	$T2_{max}$
°C	°C	°C	°C
12	70	65	46
11	71	68	46
10	72	70	46
9	73	70	46
8	75	70	46
7	76	70	47
6	78	70	48
5	79	70	49
4	84	70	50
3	87	71	51
2	89	74	52
1	91	76	52
0	93	78	53
-1	96	80	54
-2	98	82	55
-3	100	85	55
-4	102	87	56
-5	104	89	57
-6	107	91	58
-7	109	93	58
-8	111	96	59
-9	113	98	60
-10	115	100	61
-11	118	102	61
-12	120	104	62
-13	122	107	63
-14	124	109	64
-15	127	111	64
-16	129	113	65
-17	130	116	65
-18	132	118	66

EC Czechnica

t_{zew}	$T1_G$	$T1_D$	$T2_{max}$
°C	°C	°C	°C
12	70	65	46
11	71	68	46
10	72	70	46
9	73	70	46
8	75	70	46
7	76	70	47
6	78	70	48
5	79	70	49
4	84	70	50
3	87	71	51
2	89	74	52
1	91	76	52
0	93	78	53
-1	96	80	54
-2	98	82	55
-3	100	85	55
-4	102	87	56
-5	104	89	57
-6	107	91	58
-7	109	93	58
-8	111	96	59
-9	113	98	60
-10	115	100	61
-11	118	102	61
-12	120	104	62
-13	122	107	63
-14	124	109	64
-15	127	111	64
-16	129	113	65
-17	130	116	65
-18	132	118	66